

MAX FORDHAM LONDON OFFICE T. +44 (0) 20 7267 5161

Amaravati Developments Ltd job no. project leader scale at A1 J6743 GTS 1:100 status code and description

D3 - Construction Issue

New Sala Building Amaravati Buddhist Monastery

C01 Ss_75_00_00_00

07/10/22

Comms, Security, Safety, Control and Protection - Level 01 Amaravati 6s Kitchen and Sala - Layout project code orig. volume level type role number revision classification

NOTES

Provide fire alarm to BS 5839, Class L1. Detection

is to be generally provided by combined

detector/sounder/strobe as appropriate.

1. This drawing shows primary containment

Safety and Data Containment.

J-30100

routes only and indicative sizes. All secondary containment to be provided as a CDP to satisfy MF Spec 6743-MXF-XX-XX-SP-

Separate containment is to be provided for

submains, LV distribution, Fire Alarm / Life

6743 - MXF - XX - 01 - DR - E - 40100