

Fire Alarm

Fire Alarm and Emergency Light Testing

Fire Alarm Call Points

- **Instructions for Fire Alarm Testing in the Sala** [Instructions for Fire Alarm Testing in the Sala.pdf](#)
- **Sala Fire Alarm Test Sheet** [Sala Fire Alarm Test Sheet.pdf](#)
- **Workshop & Garden Stores Alarm Test Sheet** [Workshop & Garden Stores Fire Alarm Test Sheet.pdf](#)
- [Call Point Location Plan 1 \(Ground Floor\) vs3.pdf](#)
- [Call Point Location Plan 2 \(Upstairs\) vs3.pdf](#)
- [Call Point Location Plan 3 \(Workshop & Garden Stores\) vs4.pdf](#)



Emergency Lighting

- **Sala Emergency Lighting Test Sheet**
- **DRAFT Sala Emergency Lighting Plan**
- **[Emergency Light Switches Location Plan 1 \(Ground Floor\) vs3.pdf](#)**
- **[Emergency Light Switches Location Plan 2 \(Upper Floor\) vs2.pdf](#)**
- **DRAFT Workshop & Garden Stores Emergency Lighting Plan**

- **Emergency Light Switches Location Plan 3 (Workshop & Garden Stores) vs3.pdf**



Fire Alarm Panel User Instructions

- **Sala Fire Alarm Panel User Instructions** [Advanced-MxPro5-User-Manual.pdf](#)
- **Workshop Fire Alarm Panel Information** [GO1.pdf](#)
- **Call Point Installation & User Guide** [Intelligent Manual Call Point Installation Guide.pdf](#)

Smoke/Heat Detectors

[Sala & Workshop - Smoke Detector Alarms with numbers vs2.pdf](#)

[Sala & Workshop - Smoke Alarm List vs2.pdf](#)

There is a 3 minute delay on the fire alarm sensors (smoke alarms, heat sensors). This means that if one discovers a fire and the sirens are not alarming you should press a call point immediately (every second counts!). The call points do not have a delay.

If there is a fault with the fire alarm panel it will make a high pitched tone (only in the vicinity of the panel). The fire alarm company need to be alerted as soon as possible, and once this is done the tone can be silenced using the 'mute' button.

The fire suppression system in the kitchen uses foam. It will be triggered automatically if there is a substantial kitchen fire. If this is triggered it requires **A LOT** of cleaning up afterwards!!!!!!!

If a smoke alarm has been triggered (either by smoke or something else) it will have a red light showing on the sensor. This is a way that a faulty detector can be identified.

To gain more information about the location of a fire alarm test/trigger, press the menu button on the panel ('tick' icon) and then scroll to the right (??).

If there is a fire on the wok or the oven turn off the fuel supply by pressing the red button in the corner of the kitchen. To reconnect the fuel, pull the button out.

Other Files

[2024-11-09 Phase 6s Sala Fire Safety System Commission Certificate.pdf](#)

Ground Floor Fire Alarm System (Design Plan): [6743-MXF-XX-00-DR-E-40100 \(1\).pdf](#)

Upper Floor Fire Alarm System (Design Plan): [6743-MXF-XX-01-DR-E-40100 \(1\).pdf](#)

Fire Alarm Zone Map: [Sala Fire Alarm Zone Map.pdf](#) [Sala Fire Alarm Zone Map.pdf](#)

- **Outside Lighting & Escape Route to Assembly Point:** [Sala Outside Lighting & Escape Route to Assembly Point.pdf](#)

Revision #22

Created 22 November 2024 10:14:22 by Pasādo Bhikkhu

Updated 10 April 2025 15:29:49 by Pasādo Bhikkhu